

ANNEXURE - A

Functioning report of all completed schemes

Status as on 31.12.2005

A. Piped water supply schemes (Gravity, River Pumping & DTW pumping)

Sl. No.	Division	Sub Division	Name of Scheme	Type of scheme	Name of villages/ habitation covered	Functioning Status (Indicate whether fully or partially or non functioning	Reasons for partially functioning	Date on which it will be made fully functional	Reasons for Non-functioning	Date on which it will be made fully functional	Remarks
1	2	3	4	5	6	7	8	9	10	11	12
1	Electrical Division Mawphlang	Electrical SubDivision Mawphlang	Greater Shillong Water Supply Scheme	River Pumping	Urban, Sub: Urban parts of Shillong including enrouteto villages	functioning	PF8	31.3.2007	-		Due to old age of pumping machineries
2	-do-	-do-	Krang WSS	River Pumping	Krang Nonglum Jamynthlen	Fully functioning	-	-	-		
3	-do-	-do-	Lyngwa WSS	River Pumping	Lyngwa Kyrlian	Fully functioning	-	-	-		
4	-do-	-do-	Marpna WSS	River Pumping	Marpna Kroh	Fully functioning	-	-	-		
5	-do-	-do-	Jaud WSS	River Pumping	Jaud Laitdiang Warjaud	Fully functioning	-	-	-		
6	-do-	-do-	Nongbsap WSS	River pumping	Nongbsap	Fully functioning	-	-	-		
7	-do-	-do-	Mawthlong WSS	River Pumping	Mawthlong	Fully functioning	-	-	-		

8	-do-	-do-	Mawkharkrang WSS	River Pumping	Mawkharkrang Umlyndeng Marbañiang	Partially functioning	PF9	31.3.2007	-	Though the scheme is functioning, supply of water is adversely affected due to low voltage supply. State Electricity Board is making an effort to improve the supply of voltage.
9	-do-	-do-	Umsier Combined WSS	River Pumping	Umsier Mawrisnai Dewlieh Nongrngi Lummawlein Lumpyrdoin	Fully functioning	-	-	-	
10	-do-	-do-	Mawdngung WSS	DTW Pumping	Mawdngung	Fully functioning	-	-	-	
11	-do-	-do-	Mawngap-Marbisu WSS	River Pumping	Marbisu Marbisu Pdengshnong Mawngap Dukan MawngapRim Mawngap Mawsmmai	Fully functioning	-	-	-	
12	Electrical Division Mawphlang	Electrical SubDivision Mawphlang	Mawphlang WSS	River Pumping	Mawkohmon Dongiew Rim Nongrum Mawphlang MC Mawphlang	Fully functioning	-	-	-	
13	-do-	-do-	Kharnongwah WSS	River Pumping	Kharnongwah Marbañiang	Fully functioning	-	-	-	

					Umseñiong Lyngkwir				
14	-do-	-do-	Synrangkaban WSS	River Pumping	Synrangkaban Mawshaton Laitpynter	Fully functioning	-	-	-
15	-do-	-do-	Madan Sohum WSS	River Pumping	Madan Sohum Sohrarim Mawkobor Mawmihthied	Fully functioning	-	-	-
16	-do-	-do-	Lad Mawphlang WSS	River Pumping	Lad Mawphlang	Fully functioning	-	-	-
17	-do-	-do-	Mawjrong WSS	River Pumping	Mawjrong Kyrdemkhla Diengkynthong	Fully functioning	-	-	-
18	-do-	-do-	Dympep Combined WSS	River Pumping	Dympep Umdiengpoh Laitsohplich Swer Mawkdok	Fully functioning	-	-	-
19	-do-	-do-	Laitryngew- Mawkma WSS	River Pumping	Laitryngew Mawkma	Fully functioning	-	-	-

20	-do-	-do-	Laitlyndop WSS	River Pumping	Laitlyndop	Fully functioning	-	-	-	
21	-do-	-do-	Pyrda Kukon WSS	River Pumping	Pyrda Kukon	Fully functioning	-	-	-	
22	-do-	-do-	Nongthymmai Combined WSS	River Pumping	Nongthymmai Mawmyrsiang Lummawkong Laitkynsew	Partially functioning	PF9	31.3.2007	-	The present population of the habita - tions has far exceeded the designed population of the scheme resulting in the drop in the level of supply much below the designed rate of supply. A scheme to improve the supply position has been sanctioned and implemen- tation work is in progress.
23	Electrical Division Mawphlang	Electrical SubDivision Mawphlang	Laitlyngkot Combined WSS	River Pumping	Laitlyngkot Nongkynrih Iewmawiong Nongthymmai Umthli Lumthangding	Fully functioning	-	-	-	
24	-do-	-do-	Mawpynthih WSS	River Pumping	Mawpynthih	Partially functioning	PF8	31.12.2006	-	On account of the present population of the habitation compounded with with wear and tear of the pumping machineries which has since exceeded the designed life of 15 years, the present per capita rate of supply has drop drastically. A scheme to improve the supply position has been sanctioned and implementation work

is in progress.

25	-do-	-do-	Sohpian WSS	River Pumping	Sohpian Wahsohlait Lempluh L:aitlare	Fully functioning	-	-	-
26	-do-	-do-	Pamsanngut WSS	River Pumping	Pamsanngut Nongwah Mawliehpoh Nongmadan	Fully functioning	-	-	-
27	-do-	-do-	Laitarted WSS	River Pumping	Laitarted	Fully functioning	-	-	-
28	-do-	-do-	Mawpyllun WSS	River Pumping	Mawpyllun	Fully functioning	-	-	-
29	-do-	-do-	Mawlai (Umsohlang) WSS	River Pumping	Mawlai Town	Fully functioning	-	-	-
30	-do-	-do-	Mawroh WSS	River Pumping	Mawroh	Fully functioning	-	-	-
31	-do-		Pynthorbah - Lumshyiap WSS	DTW Pumping	Pynthorbah Lumshyiap	Fully functioning	-	-	-
32	-do-	-do-	Pynhorumkhrah WSS	DTW Pumping	Pynthorumkhrah	Fully functioning	-	-	-
33	-do-	-do-	Umpling WSS	DTW Pumping	Relief & Rehabilitation Colony, Lumshngain	Fully functioning	-	-	-
34	-do-	-do-	Relief & Rehabilitation	DTW Pumping	Relief & Rehabilitation	Fully functioning	-	-	-

Water supply schemes in the Mawphlang Division										
Sl. No.	Type of supply		Location		Status	Remarks	Date of completion	Remarks	Remarks	Remarks
	Division	SubDivision	WSS	Pumping						
35	-do-	-do-	St. Edmund's WSS	DTW Pumping	Lumawrie	Fully functioning	-	-	-	
36	-do-	-do-	Jaiaw Jingthangbriew WSS	DTW Pumping	Wahingdoh	Fully functioning	-	-	-	
37	Electrical	Electrical	Lady Hydari Park WSS	DTW Pumping	Civil Hospital, Shillong	Non functioning	NF7	-		Though the Health Department has made an alternative arrangement for supply water to the hospital through the installation of additional bore well with iron removal plant, the hospital authority has requested the department for reviving of the work. Consequent upon the request, the estimate duly approved by the Department was submitted to Principal Secretary, Health Department for their necessary action. Approval of Health Department is awaited.
38	-do-	-do-	Laitlum WSS	River Pumping	Laitlum	Partially functioning	PF3	30.06.2006	-	Though the scheme is functioning, supply of water is adversely affected due to reduction in discharge of the source.Improvement of the scheme has since been sanctioned and Implementation works is in progress. taken up.
39	-do-	-do-	Nongjrong WSS	River Pumping	Nongjrong	Fully functioning	-	-	-	

Mawphlang Sub-Division										
Sl. No.			Project Name			Status			Remarks	
No.			Project Name			Status			Remarks	
40	-do-	-do-	Umsaw (Umsawar) WSS	River Pumping	Umsaw	Fully functioning	-	-	-	
41	-do-	-do-	Mawblang 'A' WSS	River Pumping	Mawblang	Fully functioning	-	-	-	
42	-do-	-do-	Greater Diengiei WSS	River Pumping	Phansawrang Mawrihpih Mawlaiteng Mawlum Mawlaingut Dewsaw Lawmei Kyntonmynnar Nongsawing Kreit Mawmih	Partially functioning	PF9	31.12.2007	-	Though the scheme is functioning, supply of water is adversely affected due to low voltage supply. State Electricity Board is making an effort to improve the supply of voltage.
43	-do-	-do-	Jaiaw Laitdom WSS	DTW Pumping	Jaiaw Laitdom	Fully functioning	-	-	-	
Sub: Divisional Officer(PHE) Electrical Sub: Division Shillong			Sub: Divisional Officer(PHE) Electrical Sub: Division Mawphlang			Executive Engineer (PHE) Electrical Division			Superintending Engineer (PHE) Electrical Circle Shillong	