

ANNEXURE - A											
Functioning report of all completed schemes Status as on 31.03.2006											
A. Piped water supply schemes (Gravity, River Pumping & DTW pumping)											
Sl. No.	Division	Sub Division	Name of Scheme	Type of scheme	Name of villages/ habitation covered	Functioning Status (Indicate whether fully or partially or non functioning)	Reasons for partially functioning	Date on which it will be made fully functional	Reasons for Non-functioning	Date on which it will be made fully functional	Remarks
1	2	3	4	5	6	7	8	9	10	11	12
1	Electrical Division Mawphlang	Electrical Sub: Division Mawphlang	Greater Shillong Water Supply S	River Pumping	Urban, Sub: Urban parts of St	Partially Functioning	(PF8)	31.3.2007	-		Due to old age of pumping machineries
2	-do-	-do-	Krang WSS	River Pumping	Krang	Non- Functioning	-	-	-		
					Nonglum						
					Jamynthlen						
3	-do-	-do-	Lyngwa WSS	River Pumping	Lyngwa	Fully Functioning	-	-	-		
					Kyrsian						
4	-do-	-do-	Marpna WSS	River Pumping	Marpna	Fully Functioning	-	-	-		
					Kroh						
5	-do-	-do-	Jaud WSS	River Pumping	Jaud	Fully Functioning	-	-	-		
					Laitdiang						
					Warjaud						
6	-do-	-do-	Nongbsap WSS	DTW Pumping	Nongbsap	Fully Functioning	-	-	-		
7	-do-	-do-	Mawthlong WSS	DTW Pumping	Mawthlong	Fully Functioning	-	-	-		
8	-do-	-do-	Mawkharkrang WSS	River Pumping	Mawkharkrang	Partially Functioning	(PF9)	31.3.2007	-		Though the scheme is functioning,supply of water is adversely affected due to low voltage supply.Electricity Board is making an effort State to improve the supply of voltage.
					Umlyndeng						
					Marbañiang						
9	-do-	-do-	Umsier Combined WSS	River Pumping	Umsier	Fully Functioning	-	-	-		
					Mawrisnai						
					Dewlieh						
					Nongrngi						
					Lummawlein						
					Lumpyrdoin						
10	-do-	-do-	Mawdngung WSS	DTW Pumping	Mawdngung	Fully Functioning	-	-	-		
11	-do-	-do-	Mawngap-Marbisu WSS	River Pumping	Marbisu	Fully Functioning	-	-	-		
					Marbisu Pdengshnong						
					Mawngap Dukan						
					MawngapRim						
					Mawngap Mawsmai						
12	Electrical Division Mawphlang	Electrical Sub: Division Mawphlang	Mawphlang WSS	River Pumping	Mawkohmon	Fully Functioning	-	-	-		
					Dongiew Rim						
					Nongrum Mawphlang						
					MC Mawphlang						
13	-do-	-do-	Khamongwah WSS	River Pumping	Khamongwah	Fully Functioning	-	-	-		
					Marbañiang						
					Umseiñiong						
					Lyngkwir						
14	-do-	-do-	Synrangkaban WSS	River Pumping	Synrangkaban	Fully Functioning	-	-	-		
					Mawshaton						
					Laitpynter						
15	-do-	-do-	Madan Sohum WSS	River Pumping	Madan Sohum	Fully Functioning	-	-	-		
					Sohrarim						
					Mawkobor						

					Mawmihthied							
16	-do-	-do-	Lad Mawphlang WSS	River Pumping	Lad Mawphlang	Fully Functioning	-	-	-			
17	-do-	-do-	Mawjriong WSS	River Pumping	Mawjriong	Fully Functioning	-	-	-			
					Kyrdemkhla							
					Diengkynthong							
18	-do-	-do-	Dympep Combined WSS	River Pumping	Dympep	Fully Functioning	-	-	-			
					Umdiengpoh							
					Laitsohpiah							
					Swer							
					Mawkdok							
19	-do-	-do-	Laitryngew-Mawkma WSS	River Pumping	Laitryngew	Fully Functioning	-	-	-			
					Mawkma							
20	-do-	-do-	Laitlyndop WSS	River Pumping	Laitlyndop	Fully Functioning	-	-	-			
21	-do-	-do-	Pyrda Kukon WSS	River Pumping	Pyrda Kukon	Fully Functioning	-	-	-			
22	-do-	-do-	Nongthymmai Combined WSS	River Pumping	Nongthymmai	Partially Functioning	(PF9)		31.3.2007	-		The present population of the habitations has far exceeded the designed population of the scheme resulting in the drop in the level of supply much below the designed rate of supply. A scheme to improve the supply position has been sanctioned and implementation work is in progress.
					Mawmyrsiang							
					Lummawkong							
					Laitkynsew							
23	Electrical Division Mawphlang	Electrical Sub: Division Mawphlang	Laitlyngkot Combined WSS	River Pumping	Laitlyngkot	Fully Functioning	-	-	-			
					Nongkynrih							
					Iewmawiong							
					Nongthymmai							
					Umthli							
					Lumthangding							
24	-do-	-do-	Mawpynthih WSS	River Pumping	Mawpynthih	Partially Functioning	(PF8)		31.12.2006	-		On account of the present population of the habitation compounded with with wear and tear of the pumping machineries which has since exceeded the designed life of 15 years, the present per capita rate of supply has drop drastically. A scheme to improve the supply position has been the supply position has been sanctioned and implementation work is in progress.
25	-do-	-do-	Sohpian WSS	River Pumping	Sohpian		-	-	-			
					Wahsohlait							
					Lempluh							
					Laitlare							
26	-do-	-do-	Pamsanngut WSS	River Pumping	Pamsanngut	Fully Functioning	-	-	-			
					Nongwah							
					Mawliehpoh							
					Nongmadan							
27	-do-	-do-	Laitarted WSS	River Pumping	Laitarted	Fully Functioning	-	-	-			
28	-do-	-do-	Mawpyllun WSS	River Pumping	Mawpyllun	Fully Functioning	-	-	-			
29	- do -	- do -	Improvement of Mawngap Marbisu WSS	River Pumping	Marbisu	Fully Functioning	-	-	-			
					Marbisu Pdengshnong							
					Mawngap Dukan							
					Mawngap Rim							
					Mawngap Mawsmmai							
30	- do -	- do -	Madan Phutbol-Nongthymmai co	River Pumping	Madan Phutbol	Fully Functioning	-	-	-			
					Nongthymmai							
31	- do -	- do -	Sustainability of water source of Dympep combined WSS	River Pumping	Dympep	Fully Functioning	-		-			
					Umdiengpoh							
					Laitsohpiah							
					Swer							
					Mawkdok							

32	Electrical Division Mawphlang	Electrical Sub: Division Mawphlang	Improvement & Regeneration of the yield of Laitryngew Mawkma WSS	River Pumping	Laitryngew	Fully Functioning	-		-		
					Mawkma						
33	-do-	Electrical Sub: Division Shillong	Mawlai (Umsohlang) WSS	River Pumping	Mawlai Town	Fully Functioning	-	-	-		
34	-do-	-do-	Mawroh WSS	River Pumping	Mawroh	Fully Functioning	-	-	-		
35	-do-	-do-	Pynthorbah - Lumshyiap WSS	DTW Pumping	Pynthorbah	Fully Functioning	-	-	-		
					Lumshyiap						
36	-do-	-do-	Pynhorumkhrah WSS	DTW Pumping	Pynthorumkhrah	Fully Functioning	-	-	-		
37	-do-	-do-	Umpling WSS	DTW Pumping	Relief & Rehabilitation Colony, Lumshngain	Fully Functioning	-	-	-		
38	-do-	-do-	Relief & Rehabilitation Colony, Lumshngain WSS	DTW Pumping	Relief & Rehabilitation Colony, Lumshngain	Fully Functioning	-	-	-		
39	-do-	-do-	St. Edmund's WSS	DTW Pumping	Lumawrie	Fully Functioning	-	-	-		
40	-do-	-do-	Jaiaw Jingthangbriew WSS	DTW Pumping	Wahingdoh	Fully Functioning	-	-	-		
41	-do-	-do-	Lady Hydari Park WSS	DTW Pumping	Civil Hospital, Shillong	Non- Functioning	-		(NF7)		Though the Health Department has made an alternative arrangement for supply of water to the hospital through the installation of additional bore well with iron removal plant, the hospital authority has requested the department for reviving of the well. Consequent upon the request, the estimate duly approved by the Department was sent to Principal Secretary, Health Department for their necessary action. Approval of Health Department is awaited.
42	-do-	-do-	Laitlum WSS	River Pumping	Laitlum	Partially Functioning	(PF3)	30.06.2006			Though the scheme is functioning, supply of water is adversely affected due to reduction in discharge of thesource.Improvement of the scheme has since been sanctioned and Implementation works is in progress.
43	-do-	-do-	Nongjriong WSS	River Pumping	Nongjriong	Fully Functioning	-	-	-		
44	Electrical Division	Electrical Sub: Division	Umsaw (Umsawar) WSS	River Pumping	Umsaw	Fully Functioning	-	-	-		
45	-do-	-do-	Mawblang 'A' WSS	River Pumping	Mawblang	Fully Functioning	-	-	-		
46	-do-	-do-		River Pumping	Phansawrang	Partially Functioning	(PF9)	31.12.2007	-		Though the scheme is functioning, supply of water is adversely affected due to low voltage supply. State Electricity Board is making an effort to improve the supply of voltage.
					Mawrihipih						
					Mawlaiteng						
					Mawlum						
					Mawlaingut						
					Dewsaw						
					Lawmei						
					Kyntonmynnar						
					Nongsawing						
					Kreit						
					Mawmih						
47	-do-	-do-	Jaiaw Laitdom WSS	DTW Pumping	Jaiaw Laitdom	Fully Functioning	-	-	-		
48	- do -	- do -	Improvement of Pynthorbah - Lumshyiap WSS	DTW Pumping	Pynthorbah	Fully Functioning	-	-	-		
					Lumshyiap						
49	- do -	- do -	Improvement of Relief and Rehabilitation Colony & Lumshngain WSS	DTW Pumping	Relief&Rehabilitation colony	Fully Functioning	-	-	-		
					Lumshngain						
Sub: Divisional Officer(PHE) Electrical Sub: Division Shillong			Sub: Divisional Officer(PHE) Electrical Sub: Division Mawphlang			Executive Engineer (PHE) Electrical Division Mawphlang			Superintending Engineer (PHE) Electrical Circle Shillong		